ELAN s.r.l. – Via Osimana, 70 – 60021 Camerano (AN) – Italy R.E.A. AN n.152242 – C.F. e P.IVA 01572590428 – Cap. Soc. € 98.940,00 i.v. **Tel.** +39.071.7304358 – Fax +39.071.7304282 www.elan.an.it – info@elan.an.it – elan@registerpec.it



STANDARDS AND LEGISLATION

ITALIAN LEGISLATION	INTERNATIONAL LEGISLATION	TITLE
CEI 20-22/2		Fire test on electrical cables Part
		2: Flame retardant test.
CEI 20-22/4	IEC 332-3 HD 405.3 S1	Fire test on electrical cables Part
		4: oxygen index measurement
		for non-metallic components.
CEI EN 60332-1-2		Fire test on electrical and optical
		cables under fire conditions Part
		1-2: vertical flame retardant test
		on single conductor or cable –
		flame procedure of 1kW pre-
		mixed.
CEI EN 60332-2-2		Fire test on electrical and optical
		cables under fire conditions Part
		2-2: vertical flame retardant test
		on small single conductor or
		cable – Spread flame process.
CEI 20-36/1-1	IEC 60331-11	Fire test on electrical cables
		under fire conditions – Circuit
		integrity Part 11: Equipment for
		tests with only fire, at least
		750°C flame temperature.
CEI 20-36/2-1	IEC 60331-21	Fire test on electrical cables
		under fire conditions - Circuit
		integrity Part 21: Procedures and
		prescriptions – Cables with
		0,6/1kV tension.
CEI 20-37/4-0		Test for cables under fire
		conditions – Test on gas
		emissions during cables
		materials combustion. Part 4:
		Definition of gas emissions
		toxicity index.
CEI EN 50200		Test fire resistant of small
		unprotected cables for backup
		circuit use.
CEI UNI 36762		Indentification and tests to use
		for cable (cat.0) related to
		installation with cables cat. 1